

Loop Hangers

Product Description

Product Specification

Model No	Description	Hanger Rod Size, in (mm)	Nominal Pipe Size		Remarks
			in	(mm)	
SD-HB	Loop Hanger	3/8 (10)	3/4 through 4	(20 through 100)	a, b
SD-HB	Loop Hanger	1/2 (12)	5 through 8	(125 through 200)	a, b

Remarks:

- a) The SD-HB is FM Approved as a 200R when made with an O-ring in place of a flared nut and as a 200S with a modified ring nut.
- b) Product marked with an 'S' designation identifies a specific manufacturing location.

Details

Category	Pipe Hangers, Loop
Class of Work	1951 - Pipe hangers For AS Sys
Approval Standard	FM 1951, 1952, 1953 - Pipe Hanger Components for Automatic Sprinkler Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
 Unit 3 Endeavor Drive, Basildon, Essex, SS14 3WF, United Kingdom
 United Kingdom
<http://www.shieldglobal.com>