





Kitemark™ Certificate

This is to certify that: Shield Fire Safety & Security Ltd

Unit 3

Endeavour Drive

Basildon SS14 3WF United Kingdom

Holds Certificate Number: KM 638122

In respect of:

BS EN 1866 Mobile Fire Extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

Shahm Barhom, Group Product Certification Director

First Issued: 2015-11-11 Effective Date: 2022-09-14 Latest Issue: 2022-09-14 Expiry Date: 2025-05-22

Page: 1 of 2



For and on behalf of BSI:

Kitemark™ Certificate

No. KM 638122

Model No	Description	Branded As
SDTP25	25 kg ABC powder (85%), stored pressure. Fire rating IIB	SHIELD
SDTP50	50 kg ABC powder (85%), stored pressure. Fire rating IVB	SHIELD
SDTP100	100 kg ABC powder (85%), stored pressure. Fire rating IVB	SHIELD
SDTFC50	50 litre foam (6% AFFF), cartridge operated. Fire rating A & IVB	SHIELD
SDTFC100	100 litre foam (6% AFFF), cartridge operated. Fire rating A & IVB	SHIELD
SDTFC135	135 litre foam (6% AFFF), cartridge operated. Fire rating A & IVB	SHIELD
SDTC10	10 kg carbon dioxide. Fire rating 70B	SHIELD
SDTC30	30 kg carbon dioxide. Fire rating 113B	SHIELD

All the above products are certified to BS EN 1866-1:2007

First Issued: 2015-11-11 Effective Date: 2022-09-14 Latest Issue: 2022-09-14 Expiry Date: 2025-05-22

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.