

Model SDH-AVA

File Number: EX6719

**COMPANY**

SHIELD FIRE SAFETY & SECURITY LTD  
Unit 3, Endeavour Dr  
Basildon, SS14 3WF United Kingdom

**MODEL INFO**

SDH-AVA  
Alarm Valve

PRODUCT INFORMATION								
Body Type	Nom Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Supply Pressure Type	Alarm Device Type	Alarm Device Model	Retard Chamber Model	Installed Position
Globe	3, 4, 6, 8	Groove, Flange, Flange by Groove	250 (1723)	Variable	Water motor gong	GA	RC9	Vertical
Globe	3, 4, 6, 8	Groove, Flange, Flange by Groove	250 (1723)	Constant	Water motor gong	GA	Not Applicable	Vertical

GENERAL
<b>Installation Limitations</b>
End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."