

Model SD-NRS360FF-PIFSW

Product Description

Resilient Seated Gate Valves with Indicator Post flanges. 4 through 12 in. NPS. Valves have a rated working pressure of 363 psi (2500 kPa). Available with the following end connections.

Product Specification

Model No	Valve Size		End Connection
	in	(mm)	
SD-NRS360FF-PIFSW	4, 6, 8, 10, 12	(100, 150, 200, 250, 300)	Flange x Flange (ANSI, BS, EN, JIS)

Details

Category	Gate Valves, Inside Screw
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
Unit 3 Endeavor Drive, Basildon, Essex, SS14 3WF, United Kingdom
<http://www.shieldglobal.com>