

Kitemark™ Certificate

This is to certify that:

Shield Fire Safety & Security Ltd
Unit 3
Endeavour Drive
Basildon
SS14 3WF
United Kingdom

Holds Certificate Number:

KM 651107


In respect of:

BS 750
Underground fire hydrants and surface box, frames and covers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2016-09-28

Latest Issue: 2019-05-08

Effective Date: 2019-05-08

Expiry Date: 2022-05-07



Page: 1 of 2

...making excellence a habit.™

Kitemark™ Certificate

No. KM 651107

Description	Model No.	Additional Information	Branded As
DN80 PN16 Type 2c Fire Hydrant with captive obturator and copper alloy outlet.	SDHYD 058	Underground Hydrant	Shield

The above product is certified to BS 750:2012.



First Issued: 2016-09-28
Latest Issue: 2019-05-08

Effective Date: 2019-05-08
Expiry Date: 2022-05-07