

Kitemark™ Certificate

This is to certify that:

Shield Fire Safety & Security Ltd
Unit 3
Endeavour Drive
Basildon
SS14 3WF
United Kingdom

Holds Certificate Number:

KM 651112


In respect of:

BS EN 14384
Pillar fire hydrants

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2016-09-28

Latest Issue: 2019-05-08

Effective Date: 2019-05-08

Expiry Date: 2022-05-07



Page: 1 of 4

...making excellence a habit.™

Kitemark™ Certificate

No. KM 651112

Description	Model No.	Additional Information	Branded As
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100 SDHC-800	Hand wheel operation, Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100 SDHC-1200	Hand wheel operation, Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" Gate valve with BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHV-800	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" Gate valve with BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHV-1200	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" Gate valve with BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHV-800	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" Gate valve with BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHV-1200	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQ-800	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQ-1200	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield

First Issued: 2016-09-28

Latest Issue: 2019-05-08

Effective Date: 2019-05-08

Expiry Date: 2022-05-07

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 651112

Description	Model No.	Additional Information	Branded As
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHQ-800	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHQ-1200	Complete Ductile iron body construction, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQC-800	Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQC-1200	Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHQC-800	Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling & 4" BSRT Pumper outlet.	150SDFHQC-1200	Complete Ductile iron body construction with Aluminium / GRP protection cover, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQS-CD800	Complete Ductile iron body construction with Single body casting of Upper Barrel, PN 16 Pressure rating.	Shield
4" (DN 100) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	100SDFHQS-CD1200	Complete Ductile iron body construction with Single body casting of Upper Barrel, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHQS-CD800	Complete Ductile iron body construction with Single body casting of Upper Barrel, PN 16 Pressure rating.	Shield

First Issued: 2016-09-28

Latest Issue: 2019-05-08

Effective Date: 2019-05-08

Expiry Date: 2022-05-07

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 651112

Description	Model No.	Additional Information	Branded As
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling and 4" BSRT Pumper outlet.	150SDFHQS-CD1200	Complete Ductile iron body construction with Single body casting of Upper Barrel, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling, 1 x 4" BSRT pumper connection and 1 x 4" Flanged outlet.	150SDFHQM-800	Complete Ductile iron body construction with 4" flanged outlet for Monitor connection, PN 16 Pressure rating.	Shield
6" (DN 150) Dry pillar hydrant inlet with 2 x 2½" BS 336 Coupling, 1 x 4" BSRT Pumper connection and 1 x 4" Flanged inlet.	150SDFHQM-1200	Complete Ductile iron body construction with 4" flanged outlet for Monitor connection, PN 16 Pressure rating.	Shield

Pillar Fire Hydrants are certified to BS EN 14384:2005.

First Issued: 2016-09-28

Latest Issue: 2019-05-08

Effective Date: 2019-05-08

Expiry Date: 2022-05-07

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.